

CITY OF LOS ANGELES

CALIFORNIA

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

—
VAN AMBATIELOS
PRESIDENT

JAVIER NUNEZ
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
ELVIN W. MOON



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

—
FRANK M. BUSH
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.
EXECUTIVE OFFICER

Tru-Weld Division.
TFP Corp.
460 Lake Road
Medina, Ohio 44256

Attn: Steven A. Kern
(330) 725-7741 x202

RESEARCH REPORT: RR 25887
(CSI # 03 15 00)

BASED UPON ICC EVALUATION SERVICE
REPORT NO. ESR-2823

REEVALUATION DUE
DATE: January 1, 2022
Issued Date: March 1, 2020
Code: 2017 LABC

GENERAL APPROVAL – Reevaluation - Deformed Bar Anchors

DETAILS

The above assemblies and/or products are approved when in compliance with the use, description, design, installation, conditions of use, and identification of ICC Evaluation Services Report No. ESR-2823, reissued December 2018, of the ICC Evaluation Service, LLC. The report in its entirety is attached and made part of this general approval.

The approval is subject to the following conditions:

1. Use of the anchors is limited to installation in uncracked concrete and non-seismic applications
2. Use of the anchors subjected to fatigue, shock, or vibratory loads is not covered under this approval
3. Allowable tension and shear loads, for 3/8” and 1/2” anchors, given on Table 1 and Table 2, respectively, of the ICC-ES Evaluation Report ESR 2823 are valid when the anchors are installed in normal weight concrete having a minimum concrete strength of 3,000 psi

RR 25887
Page 1 of 3

4. Allowable tension and shear loads, for 5/8" and 3/4" anchors, given on Table 1 and Table 2, respectively, of the ICC-ES Evaluation Report ESR 2823 are valid when the anchors are installed in normal weight concrete having a minimum concrete strength of 5,000 psi
5. Continuous inspection by Deputy Inspectors shall be provided during installations of the Deformed Bar Anchors in accordance with Section 1704 of the 2017 Los Angeles City Building Code.
6. Deformed Bar Anchors locations shall be fully detailed on the plans and approved by Plan check engineer. The calculations for Deformed Bar Anchors shall be prepared by a Civil or Structural Engineer registered in the State of California.
7. The fabricator, in processing steel for the Deformed Bar Anchors through his works, shall maintain identity of the material and shall maintain suitable procedures and records attesting that the specified grade has been furnished in conformity with the applicable ASTM Standard. The ASTM or other specification designation shall be included near the erection mark on each shipping assembly or important construction component over any shop coat of paint prior to shipment from the fabricator's plant. The fabricator's identification mark system shall be established and on record prior to fabrication.
8. Steel which is not readily identifiable as to grade from marking and test records shall be tested to determine conformity to such standard. The fabricator shall, when requested, furnish an affidavit of compliance with such standard. Test data shall be provided upon request.
9. Except as specified herein, installation of the Deformed Bar Anchors shall be in accordance with the manufacturer's specifications. A copy of the specifications shall be provided at the job site and be made available to all Deputy Inspectors on the job.

DISCUSSION

This report is in compliance with the 2017 Los Angeles City Building Code.

The approval is based on data in accordance with applicable sections of the ICC ES Acceptance Criteria for Fiber-Reinforced Composite Connectors Anchored in Concrete (AC 320), dated October 2015, including ASTM E 488 tests and analysis; Mechanical Anchors in Concrete Elements (AC 193), dated June 2012 (Editorially revised April 2015); and AWS D1.1-2010 and ASTM A 496.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revision to the report must be submitted to this Department for review with appropriate fee to continue the approval of the revised report.

Tru-Weld Division, TFP Corporation
RE: Deformed Bar Anchors

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

DAVID CHANG, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-202-9812
Fax- 213-202-9943

EB
RR25887
TLB2000034
R03/03/2020
1901.3

Attachment: ICC ES Report No. ESR-2823 (3 Pages)